

APPENDIX - VIII


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 962

Date: 20/04/2026

It is certified that an inspection team headed by Devesh Chandra
Chemist (Name of Officers
with designation) from P.H. Division Bihar Sharif Nalanda (Name of
Department/Office) inspected the St. Joseph's School
Islampur, Nalanda, 801303 (Name & Address of
the School) on 20/04/2026 and found that the St. Joseph's
School, Islampur Nalanda, (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of one year.

Signature with Seal: 

Name

: Raghvendra Kumar

Designation

: Executive Engineer
P.H. Division, Bihar Sharif

To

St. Joseph's school

Islampur Nalanda

801303

(Name & Address of the Institution)

DLWTL-23/26 Kate-20/04/26

Government of Bihar
Public Health Engineering Department
Water Quality Report


District Name: Nalanda

Division Name: Public Health Engineering Division, Biharsharif & Hilsa

Sample Collected by :- Ref.no-SJS/TDS/01 DATE-18/4/26 RENNY JOHN

Date of Sampling :- 18/04/2026

Sl. No.	Block	Panchayat	Village	Habitation	Wd No	Location of Source	Test result													Source of Water
							pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	
1	ISLAMPUR	ISLAMPUR	ISLAMPUR	ISLAMPUR		ST.JOSEPH'S SCHOOL ISLAMPUR	7.65	0.19	396	277	130	32	12	40	140	0.09	<1.0	10.2	0.496	Tep water
Desirable Limit							6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	-
Permissible Limit* in absence of alternate source							NR	5	-	2000	600	200	100	1000	600	NR	NR	400	1.5	-


Chemist
Public Health Division, Biharsharif
(Nalanda)
20/04/2026